

Product Certification Schedule

Schedule No: 189/001/068

Licensee: DRAKA UK LTD, CHICKENHALL LANE, EASTLEIGH, HAMPSHIRE, SO50 6YU

Factory: CHICKENHALL LANE, EASTLEIGH, HAMPSHIRE, SO50 6YU

Specification: BS 7629-1:2015 Electric Cables - Specification for 300/500 V fire resistant, screened, fixed installation cables having low emission of smoke and corrosive gases when affected by fire. Part 1 : Multicore cables

Type of Cable: Table 2 - Dimensions of 2-core, 3-core and 4-core cables

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 1.0sqmm nominal cross-sectional area of conductors inclusive. 2-core.
1.5sqmm to 4sqmm nominal cross-sectional area of conductors inclusive.
2-core to 4-core inclusive.
STANDARD 60.
Additionally tested to BS 6387:2013 Categories C, W & Z.
Sheath - LTS3. Insulation - EI5.

Origin Thread: Not applicable

Origin Mark: DRAKA UK (B) FT30 SAFFIRE

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 11/08/2020

Signed for and on behalf of the British Approvals Service for Cables

Date 02/08/2017

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004